



NOTE
TAPS IN STAGGERED CONFIGURATION AT
10 O'CLOCK OR
2 O'CLOCK POSITION

NOTES:

1. SANITARY SEWER SERVICE TAPS SHALL BE LOCATED ON THE MAIN AT THE 2 O'CLOCK OR 10 O'CLOCK POSITION.
2. THE MINIMUM DISTANCE BETWEEN ANY TWO CONSECUTIVE FITTINGS SHALL BE 3 FEET, MEASURED BETWEEN FITTING CENTERLINES.
3. SANITARY SEWER SERVICE TAPS SHALL NOT BE MADE WITHIN 3 FEET OF A PIPE JOINT, OR 5 FEET FROM EDGE OF MANHOLE BASE.
4. A MAXIMUM OF FOUR SERVICE TAPS ARE ALLOWED PER 20 FOOT LENGTH OF PIPE.
5. ALL SANITARY SEWER TAPS SHALL USE "WYE" STYLE FITTINGS. TEES ARE NOT ALLOWED.
6. SERVICE CONNECTIONS TO MANHOLES SHALL BE PERFORMED IN ACCORDANCE WITH THE "SERVICE CONNECTION TO DEAD-END MANHOLE" CONSTRUCTION DETAIL.

Kennedy/Jenks Consultants

Engineers & Scientists

165 S Union Boulevard
Suite 570
Lakewood, CO 80228
303.985.3636 TEL

SOUTH ENGLEWOOD SANITATION DISTRICT

www.southenglewood.org

SERVICE
CONNECTIONS TO
NEW CONSTRUCTION

DRAWING NO.: SESD-PRI-1S DATE: 8/19