



**NOTE:**

1. CASTING SPECIFICATIONS: ASTM A-48 WITH A MINIMUM TENSILE STRENGTH OF 25 KSI (CLASS 25) PER CITY OF CENTENNIAL STANDARDS
2. ALL CASTINGS TO BE DIPPED IN ASPHALT BASE PAINT (OR APPROVED EQUAL)
3. TOP OF MANHOLE COVER SHALL BE 1/4" TO 1/2" BELOW GRADE OR PER CITY/COUNTY REQUIREMENTS
4. ALL BEARING SURFACES TO BE MACHINED.
5. LETTERING ON COVER AS REQUIRED (WATER,SEWER)
6. TOTAL MINIMUM WT. APPROX. 630 LBS.
7. COMCO CAT #C1360 OR EQUAL
8. LIFTING NOTCH SHALL NOT EXTEND PAST INSIDE FACE OF RING.

**Kennedy/Jenks Consultants**  
**Engineers & Scientists**

165 S Union Boulevard  
 Suite 570  
 Lakewood, CO 80228  
 303 985 3636 TEL

SOUTH ENGLEWOOD SANITATION DISTRICT

[www.southenglewood.org](http://www.southenglewood.org)

30" MANHOLE  
 RING & COVER  
 DETAIL

DRAWING NO.: SESD-PUB-10S DATE: 8/19